



# TEST REPORT IEC 60269-2

### Low-voltage fuses

Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) - Examples of standardized systems of fuses A to I

Report Reference No. ...... 2.03.00938.1.0/CH8/400/gG/CB/CCA

CB Testing Laboratory...... ÖFPZ Arsenal Ges.m.b.H.

Applicant's name ..... ETI Elektroelement d.d.

Address ...... 1411 Izlake, Obrezija 5, SLOVENIA

Test specification:

Standard ....... IEC 60269-2:2006 (third edition) (see also IEC 60269-1:2006)

Test Report Form No. ..... IEC60269\_2A

Test Report Form(s) Originator ..... EZU

Master TRF...... Dated 2007-12

Copyright © 2007 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

Test item description ...... Cylindrical fuse-links

Trade Mark ..... ETI

Manufacturer ...... ETI Elektroelement d.d.

Model/Type reference ...... CH8 / 8x32

Ratings ...... 2A, 4A, 6A, 8A, 10A, 12A, 16A, 20A / 400VAC / gG

Testing procedure and testing location:				
☐ CB Testing Laboratory:				
Testing location / address:		ÖFPZ Arsenal Ges.m.b.H., Giefinggase 2, A-1210 Wien	6	
☐ Associated C	B Test Laboratory:			
Testing location / address:			California (California)	
			20.11	
Tested by (nar	ne + signature):	Ing.J.Ainetter	Another	
Approved by (r	name + signature) :	Ing.K.Farthofer		
☐ Testing proced	dure: TMP			
Tested by (nar	me + signature):			
Approved by (r	name + signature):		÷	
Testing location / address:				
☐ Testing proced	dure: WMT			
Tested by (nar	me + signature):			
Witnessed by	(name + signature):			
Approved by (	name + signature):			
Testing location / address:				
☐ Testing proced	dure: SMT		<del></del>	
Tested by (nar	ne + signature):			
Approved by (	name + signature) :			
Approved by (i	iame i signature/			
Supervised by	(name + signature):			
Testing location / address:				
☐ Testing proced	dure: RMT		-	
Tested by (nar	me + signature):			
Approved by (r	name + signature):			
Supervised by	(name + signature):			
Testing location / address:				

# Summary of testing:

### Tests performed:

A type test was performed according to

- IEC 60269-1:2006, 4<sup>th</sup> Edition
- EN 60269-1:2007

#### and

- IEC 60269-2:2006, 3<sup>rd</sup> Edition
- HD 60269-2:2007

The cylindrical fuse-links

CH8 / 8x32

have passed the type test successfully.

# Testing location:

ÖFPZ Arsenal Ges.m.b.H., Business Unit Monitoring, Energy and Drive Technologies, Power Service Center, Giefinggasse 2, A-1210 Wien

The ÖFPZ Arsenal Ges.m.b.H. is a recognized CB / CCA Testing Laboratory under the responsibility of OVE as the National Certification Body.

# **Summary of compliance with National Differences:**

\_\_\_

## Test performance:

The type test was performed according to IEC 60269-1 and IEC 60269-2 (CB-scheme) as well as according to EN 60269-1 and HD 60269-2 (CCA-scheme).

In case of differences in test requirements between IEC and EN, all tests were performed under the more severe conditions.

This test report is valid as a CB Test Report as well as a CCA Test Report.

### Copy of marking plate



TRF No. IEC60269 2A

Ratings:		
Identification reference:	2A: 002610001	
	4A: 002610003	
	6A: 002610005	
	8A: 002610006 10A: 002610007	
	12A: 002610007	
	16A: 002610009	
	20A: 002610011	
Nature of supply:		
Size :::		
Utilization category: Rated currents:		
Rated voltage :::		
Rated frequency:		
Rated breaking capacity:		
Homogeneous series		
	4A 6A	
	8A	
	10A to 16A	
	20A	
Type of contacts		
Material of contacts		
Extinguishing means		
Test item particulars:		
Classification of installation and use:	Fund links for use by authorized persons	
	•	
Supply Connection:		
Fuse system:	<u> </u>	
Possible test case verdicts:		
- test case does not apply to the test object:	N (Not applicable)	
- test object does meet the requirement:	P (Pass)	
- test object does not meet the requirement:	F (Fail)	
Testing:		
Date of receipt of test item:	05/2008	
Date(s) of performance of tests:	05/2008 to 08/2008	
General remarks:		
The test results presented in this report relate only to the		
This report shall not be reproduced, except in full, witho	ut the written approval of the Issuing testing laboratory	

"(see Enclosure #)" refers to additional information appended to the report. "(see appended table)" refers to a table appended to the report.

Throughout this report a comma is used as the decimal separator.