

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Built-in switches
Name and address of the applicant	ETI Elektroelement d.o.o. Obrezija 5, SI-1411 Izlake Slovenia
Name and address of the manufacturer	ETI Elektroelement d.o.o. Obrezija 5, SI-1411 Izlake Slovenia
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 ETI-Polam Sp.z.o.o. Ul Jana Pawla II 18, 06-100 Pułtusk Poland
Ratings and principal characteristics	Ie = 63 A, 80 A, 100 A, 125 A, Ue = 240 V (1p), 415 V (2p, 3p, 4p), AC-22B, Ui = 440 V, Uimp = 4 kV, Icw = 1500 A - 1 s, Icm = 2200 A peak, rated conditional short-circuit current 2500 A
Trademark (if any)	ETI
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	SV xyy (x - number of poles, yy rated current)
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-3:2008, IEC 60947-3:2008/AMD1:2012, IEC 60947-3:2008/AMD2:2015
As shown in the Test Report Ref. No. which forms part of this Certificate	2237509.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands