CERTIFICATE

Issued to: Applicant: ETI Elektroelement d.o.o. Obrezija 5 1411 Izlake, Slovenia

Licensee: ETI Elektroelement d.o.o. Obrezija 5 1411 Izlake, Slovenia

Product:residual current operated circuit-breakers (RCCB)Trade name(s):ETIType(s)/model(s):EFI-2 and EFI-4

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of

- a type test according to the standard EN 61008-1:2012, EN 61008-1:2012/A1:2014, EN 61008-1:2012/A2:2014, EN 61008-1:2012/A11:2015, EN 61008-2-1:1994/and EN 61008-2-1:1994/A11:1998
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 963600

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 19 December 2018 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-106707

DEKRA Certification B.V.

B.T.M. Holtus Managing Director

© Integral publication of this certificate is allowed

ACCREDITED BY THE DUTCH ACCREDITATION COUNCIL

H.R.M. Barends Certification Manager





DEKRA Certification B.V. Meander 1051, 6825 MJ Arnhem P.O. Box 5185, 6802 ED Arnhem, The Netherlands T +31 88 96 83000 F +31 88 96 83100 www.dekra-certification.com Company registration 09085396

DEKRA



Product data	
Product	: residual current operated circuit-breakers (RCCB)
Trade name(s)	: ETI
Type(s)/model(s)	: EFI-2 and EFI-4
Design	: without integral overcurrent protection
	functionally independent of the line voltage
Rated current (In)	: 16 A, 25 A, 40 A, 63 A and 80 A
Rated residual current (IΔn)	: 30 mA, 100 mA, 300 mA and 500 mA
Rated operational voltage (Ue)	: 230/240 Vac (1P+N)
	400/415 Vac (3P+N)
Number of poles	: 1P+N (EFI-2)
•	3P+N (EFI-4)
Behaviour to d.c. components	: type A and AC
Time-delay	: no time-delay
Rated making and breaking capacity	: 800 A
(Im)	
Rated residual making and breaking	: 800 A
capacity (IΔm)	
Rated conditional short-circuit	: 10 kA when provided with fuse-links type ETI NH 00 gG, 100 A
capacity (Inc)	
Rated conditional residual short-	: 10 kA when provided with fuse-links type ETI NH 00 gG, 100 A
circuit current ($I\Delta c$)	
Safety distance ("a",grid)	: 35 mm
Method of mounting	: flush type, for mounting on top hat rail 35 mm
Terminals	: pillar type
Temperature limit	$\therefore -25 \degree C \text{ to } +40 \degree C$
Degree of protection	: IP20
Markings	: tradename and electrical ratings are shown on the body
IVIAI NI 195	. Induction and electrical failings are shown on the body

TESTS

Test requirements

EN 61008-1:2012 EN 61008-1:2012/A1:2014 EN 61008-1:2012/A2:2014 EN 61008-1:2012/A11:2015 EN 61008-2-1:1994 EN 61008-2-1:1994/A11:1998

Test result

The test results are laid down in DEKRA test file 223346700.

Additional information

This certificate replaces certificate No. 2131835.01 which we herewith declare invalid.

Conclusion

The examination proved that all requirements were met.

Factory location

ETI Elektroelement d.o.o. Obrezija 5 1411 Izlake, Slovenia page 1 of 1

