



Test Report issued under the responsibility of:



**TEST REPORT**  
**IEC/EN 60898-1**  
**Circuit-breakers for over current protection for**  
**household and similar installations**

**Report Reference No.** ..... : 2.03.024444.1.0/ETIMATP10/CB/CCA

**Date of issue** ..... : 04.03.2013

**Total number of pages** ..... : 362

**CB/CCA Testing Laboratory** ..... : AIT Austrian Institute of Technology GmbH

**Address** ..... : A-1210 Vienna, Giefinggasse 2, AUSTRIA

**Applicant's name** ..... : ETI Elektroelement d.d.

**Address** ..... : SI-1411 Izlake, Obrezija 5, SLOVENIA

**Test specification:**

**Standard** ..... : ☒ IEC 60898-1:2002 (1st Edition) + A1:2002 + A2:2003 and/or  
☒ EN 60898-1:2003 + A1:2004 + A11:2005

**Test procedure** ..... : CB / CCA

**Non-standard test method** ..... : N/A

**Test Report Form No.** ..... : IECEN60898\_1C

**Test Report Form(s) Originator** ..... : OVE

**Master TRF** ..... : Dated 2007-12

**Copyright © 2007 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.**

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

**This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.**

If this Test Report Form is used by non-CCA members, the CIG logo and the reference to the CCA Procedure shall be removed.

**This report is not valid as a CCA Test Report unless signed by an approved CCA Testing Laboratory and appended to a CCA Test Certificate issued by an NCB in accordance with CCA**

**Test item description** ..... : Circuit-breakers for overcurrent protection for household and similar installation

**Trade Mark** ..... : ETI

**Manufacturer** ..... : ETI DE GmbH, D-63828 Kleinkahl, Dorfwiesenweg 13, GERMANY

**Model/Type reference** ..... : ETIMAT P10

**Ratings** ..... : 6A ... 63A (B), 0,5A ... 63A (C), 0,5A ... 32A (D) / 230V a.c., 230/400V a.c., 400V a.c. / 1p, 1p+N, 2p, 3p, 3p+N / Energy limiting class 3

**Testing procedure and testing location:**☒ **CB/CCA Testing Laboratory:**

Testing location/ address ..... : AIT Austrian Institute of Technology GmbH  
A-1210, Vienna, Giefinggasse 2

☐ **Associated CB Laboratory:**

Testing location/ address ..... : ---

Tested by (name + signature) ..... : Ing.J.Ainetter

.....

Approved by (+ signature) ..... : Ing.K.Farthofer

.....

☐ **Testing procedure: TMP**

Tested by (name + signature) ..... : ---

.....

Approved by (+ signature) ..... : ---

.....

Testing location/ address ..... : ---

☐ **Testing procedure: WMT**

Tested by (name + signature) ..... : ---

.....

Witnessed by (+ signature) ..... : ---

.....

Approved by (+ signature) ..... : ---

.....

Testing location/ address ..... : ---

☐ **Testing procedure: SMT**

Tested by (name + signature) ..... : ---

.....

Approved by (+ signature) ..... : ---

.....

Supervised by (+ signature) ..... : ---

.....

Testing location/ address ..... : ---

☐ **Testing procedure: RMT**

Tested by (name + signature) ..... : ---

.....

Approved by (+ signature) ..... : ---

.....

Supervised by (+ signature) ..... : ---

.....

Testing location/ address ..... : ---

<b>Summary of testing:</b>	
<b>Tests performed:</b> A type test was performed according to <ul style="list-style-type: none"> <li>▪ the standards stated on page 1</li> </ul> and also according to <ul style="list-style-type: none"> <li>▪ IEC 60898-1 Ed. 1.2:2003</li> <li>▪ EN 60898-1:2003+A1:2004+A11:2005 +A12:2008+A13:2012.</li> </ul>  The circuit-breakers for overcurrent protection for household and similar installation <ul style="list-style-type: none"> <li>▪ ETIMAT P10</li> </ul> have passed the type test successfully.	<b>Testing location:</b> AIT Austrian Institute of Technology GmbH Business Unit Electric Energy Systems Power Service Center Giefinggasse 2 A-1210 Vienna   The AIT Austrian Institute of Technology GmbH is a recognized CB/CCA Testing Laboratory under the responsibility of OVE as the National Certification Body.
<b>Possible test case verdicts:</b> Test case does not apply to the test object ..... : N/A Test item does meet the requirement ..... : P(ass) Test item does not meet the requirement ..... : F(fail)	
<b>Testing:</b> Date of receipt of test item ..... : 06/2012 Date(s) of performance of test ..... : 06/2012 to 11/2012	
<b>Summary of compliance with National Differences:</b> ---	