

LICENCE

No. 19412 replaces No.14136

Issued to:
Applicant:
ETI Elektroelement d.d.
Obrezija 5
1411 IZLAKE
Slovenia

Licensee:
ETI Elektroelement d.d.
Obrezija 5
1411 IZLAKE
Slovenia



Product : circuit-breakers for overcurrent protection
Trade name(s) : ETI
Type(s)/model(s) : ETIMAT 6

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.


SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 1337

SGS CEBEC hereby grants the right to use the CEBEC certification mark

The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on: 17/03/2015



ir. C. Lana,
Certification Manager

© Only integral publication of this certificate, including the annex, is allowed
This certificate is only valid combined with the publication on the following web address: www.sgs.com/ee



SGS Belgium NV-Division SGS CEBEC
Business Riverside Park
Bld Internationalelaan 55 Build. D
B-1070 Brussels
Tel.+32(0)2 556 00 20 Fax.+32(0)2 556 00 36

This certificate is issued by the company under its General Conditions for Certification Services accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitations of liability defined therein and in the Test Report herein mentioned which findings are reflected in this Certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	:	circuit-breakers for overcurrent protection
Trade name(s)	:	ETI
Type(s)/Model(s)	:	ETIMAT 6
number of poles	:	1P, 1P+N, 2P, 3P, 3P+N
rated voltage (Un)	:	230/400V (1P), 230V (1P+N), 400V (2P, 3P, 3P+N)
rated current (In)	:	6 up to 63 A
nature of supply	:	AC
rated frequency	:	50 Hz
range of instantaneous tripping overcurrent (curve)	:	B & C
rated short-circuit current (Icn)	:	6000 A
safety distance 'a'	:	35 mm
method of mounting	:	panel board
energy limiting class	:	3
terminals	:	Pillar terminals

Additional information

See Appendix

TESTS

Test requirements

NBN EN 60898-1 based on EN 60898-1:2003

NBN EN 60898-1 based on EN 60898-1:2003 + corrigendum 2004-02 + corrigendum 2004 + A1:2004 + A11:2005 + A12:2008 + A13:2012

Test results

The test results are laid down in certification file ref.612155/01

Remarks

This certificate is based on certificate ref. STC / AT 1010 and test report(s) ref. 2.03.02769.1.0/ETIMAT6/CB/CCA


Conclusion

The examination proved that all test requirements were met.

Checked by, project leader : Zanutto Luigi - 17/03/2015

Department Manager,
Product Certification :

Certification Manager :



2015-03-17

FACTORY LOCATION(S)

ETI Polam Sp. z.o.o.
Al. Jana Pawla II 18
06-100 PULTUSK
Poland

Products reference list. MCB's Series ETIMAT 6**Characteristic B**

Type	Rated Voltage (V)	Rated Current (A)	Code No.
1 pole	230/400	6	002111512
	230/400	10	002111514
	230/400	13	002111515
	230/400	16	002111516
	230/400	20	002111517
	230/400	25	002111518
	230/400	32	002111519
	230/400	40	002111520
	230/400	50	002111521
	230/400	63	002111522
1 pole + N	230	6	002112512
	230	10	002112514
	230	13	002112515
	230	16	002112516
	230	20	002112517
	230	25	002112518
	230	32	002112519
	230	40	002112520
	230	50	002112521
	230	63	002112522
2 pole	400	6	002113512
	400	10	002113514
	400	13	002113515
	400	16	002113516
	400	20	002113517
	400	25	002113518
	400	32	002113519
	400	40	002113520
	400	50	002113521
	400	63	002113522
3 pole	400	6	002115512
	400	10	002115514
	400	13	002115515
	400	16	002115516
	400	20	002115517
	400	25	002115518
	400	32	002115519
	400	40	002115520
	400	50	002115521
	400	63	002115522
3 pole + N	400	6	002116512
	400	10	002116514
	400	13	002116515
	400	16	002116516
	400	20	002116517
	400	25	002116518
	400	32	002116519
	400	40	002116520
	400	50	002116521
	400	63	002116522

Characteristic C

Type	Rated Voltage (V)	Rated Current (A)	Code No.
1 pole	230/400	6	002141512
	230/400	10	002141514
	230/400	13	002141515
	230/400	16	002141516
	230/400	20	002141517
	230/400	25	002141518
	230/400	32	002141519
	230/400	40	002141520
	230/400	50	002141521
	230/400	63	002141522
1 pole + N	230	6	002142512
	230	10	002142514
	230	13	002142515
	230	16	002142516
	230	20	002142517
	230	25	002142518
	230	32	002142519
	230	40	002142520
	230	50	002142521
	230	63	002142522
2 pole	400	6	002143512
	400	10	002143514
	400	13	002143515
	400	16	002143516
	400	20	002143517
	400	25	002143518
	400	32	002143519
	400	40	002143520
	400	50	002143521
	400	63	002143522
3 pole	400	6	002145512
	400	10	002145514
	400	13	002145515
	400	16	002145516
	400	20	002145517
	400	25	002145518
	400	32	002145519
	400	40	002145520
	400	50	002145521
	400	63	002145522
3 pole + N	400	6	002146512
	400	10	002146514
	400	13	002146515
	400	16	002146516
	400	20	002146517
	400	25	002146518
	400	32	002146519
	400	40	002146520
	400	50	002146521
	400	63	002146522