



EU - Declaration of conformity

<u>Manufacturer:</u>	ETI Elektroelement d.o.o.
<u>Address:</u>	Obrezija 5, 1411 Izlake, SLOVENIA
<u>Products:</u>	NV (NH) gG Low-voltage Fuse Links, KOMBI Type (with combined indicating devices, with non-insulated gripping-lugs) Size NV00 / NH00 63A, 80A, 100A, 125A / 800 V a.c. Size NV1 / NH1 160A, 200A, 250A, 315A / 800 V a.c. Size NV2 / NH2 350A, 400A / 800 V a.c. Size NV3 / NH3 350A, 400A, 450A, 500A / 800 V a.c.

This declaration of conformity is issued under the sole responsibility of the manufacturer.

The objects of the declaration described above are in conformity with the relevant Union harmonization legislations:

2014/35/EU

Directive of the European Parliament and of the Council of 26 February 2014 on the harmonisation of the laws of Member States relating to the making available on the market of electrical equipment designed for use within certain voltage limits; Official Journal of the EU L96, 29/03/2014, p. 357-374 **(from 20.04.2016)**.

2011/65/EU

Directive of the European Parliament and of the Council of 8 June 2011 on the restriction of the use of certain hazardous substances in electrical and electronic equipment (recast).

2015/863/EU

Directive of the European Parliament and of the Council of 31 March 2015 on the restriction of the use of certain hazardous substances in electrical and electronic equipment, amending Annex II of Directive EU 2011/65/EU - RoHS3, **(from 22.07.2019)**

Our products are constructed and manufactured based on our Quality Management System (according to DIN EN ISO 9001) in correspondence to the following standards:

Harmonized European standards:

DIN EN 60269-1:2015-05, DIN VDE 0636-2:2014-09

IEC standards:

IEC 60269-1 Ed. 4.2:2014-06, IEC 60269-4 Ed. 5.2:2016-08

National standards:

VDE 0636-1:2015-05, VDE 0636-2:2014-09

Test report:

IPH Institut Berlin, Test report 08954-18-0604,
DNV-GL KEMA Laboratories Prague, Test report Nr.5197-18
ICEM Maribor internal test reports

Marking with CE:

On the product / On the packaging

Affixing of the CE-marking:

2017

Place and date:

Izlake, 04.03.2021

Manufacturer representative signature and stamp:

Viktor Martinčič, univ.dipl.ing.

ELEKTROELEMENT d.o.o.
IZLAKA